

**TABLE N1
REQUIRED INSPECTION AND TEST INTERVALS IN "MONTHS"**

Periodic Test on Behalf of Owner (4)													
Reference Code	Equipment Type	Periodic Inspection By Department		Category 1 (2)		Category 3 (Unexposed Pistons of Roped Water Hydraulic elevators and Pressure Vessels)		Category 5 (5)		Notifications (1)(3)	Filing (1)(3)	Performing (1)(3)	Witnessing Agency (1)(3)
		Requirement	Interval	Requirement	Interval	Requirement	Interval	Requirement	Interval				
ASME A17.1	Electric Elevators	8.11.2.1	1-1 to 12-31	8.11.2.2	1-1 to 12-31	N/A	N/A	8.11.2.3	60	Yes (Cat. 5)	Yes	Yes	Yes
ASME A17.1	Hydraulic Elevators	8.11.3.1	1-1 to 12-31	8.11.3.2	1-1 to 12-31	8.11.3.3	36	Roped 8.11.3.4	60	Yes (Cat. 3,5)	Yes	Yes	Yes
ASME A17.1	Escalators & Moving Walks	8.11.4.1	1-1 to 12-31	8.11.4.2	1-1 to 12-31	N/A	N/A	N/A	N/A	Yes (Cat. 1)	Yes	Yes	Yes
ASME A17.1	Sidewalk Elevators	8.11.5.1	1-1 to 12-31	8.11.5.1	1-1 to 12-31	N/A	N/A	8.11.5.1	60	Yes (Cat. 5)	Yes	Yes	Yes
ASME A17.1	Dumbwaiters	8.11.5.4	1-1 to 12-31	8.11.5.4	1-1 to 12-31	N/A	N/A	8.11.5.4	60	No	Yes	Yes	No
ASME A17.1	Material Lifts	8.11.5.5	1-1 to 12-31	8.11.5.5	1-1 to 12-31	N/A	N/A	8.11.5.5	60	No	Yes	No	No
ASME A17.1	Special Purpose Personnel Elevators	8.11.5.6	1-1 to 12-31	8.11.5.6	1-1 to 12-31	N/A	N/A	8.11.5.6	60	No	Yes	Yes	No
ASME A17.1	Inclined Elevators	8.11.5.7	1-1 to 12-31	8.11.5.7	1-1 to 12-31	N/A	N/A	8.11.5.7	60	No	Yes	Yes	No
ASME A17.1	Shipboard Elevators	8.11.5.8	1-1 to 12-31	8.11.5.8	1-1 to 12-31	N/A	N/A	8.11.5.8	60	No	Yes	Yes	No
ASME A17.1	Screw-Column Elevators	8.11.5.9	1-1 to 12-31	8.11.5.9	1-1 to 12-31	N/A	N/A	8.11.5.9	60	No	Yes	Yes	No
ASME A17.1	Rooftop Elevators	8.11.5.10	1-1 to 12-31	8.11.5.10	1-1 to 12-31	N/A	N/A	8.11.5.10	60	No	Yes	Yes	No
ASME A17.1	Rack and Pinion Elevators	8.11.5.11	1-1 to 12-31	8.11.5.11	1-1 to 12-31	N/A	N/A	8.11.5.11	60	No	Yes	Yes	No
ASME A17.1	Limited Use-Limited Application Elevators (Commercial Bldgs. Only)	8.11.5.12	1-1 to 12-31	8.11.5.12	1-1 to 12-31	N/A	N/A	8.11.5.12	60	Yes (Cat. 5)	Yes	Yes	Yes
ASME A17.1	Elevators Used for Construction	8.11.5.13	N/A	8.11.5.13	1-1 to 12-31	N/A	N/A	8.11.5.13	60	No	Yes	Yes	Yes
ASME A18.1	Platform Lifts	10.2	1-1 to 12-31	10.3.1	1-1 to 12-31	10.3.2	36	10.3.3	60	No	Yes	Yes	No
ASME B20.1	Vertical and Inclined Reciprocating Conveyors (VRC)	N/A	N/A	Appendix K2	Appendix K2	N/A	N/A	Appendix K2	Appendix K2	No	No	No	No
ASME A90.1	ManLifts	8.2	1-1 to 12-31	8.1	1-1 to 12-31	N/A	N/A	N/A	N/A	No	Yes	Yes	Yes
	Private Residence	N/A	N/A										
ASME A17.1	PR Elevators	N/A	N/A	8.11.5.2	1-1 to 12-31	N/A	N/A	8.11.5.2	60	No	Yes	Yes	No
ASME A17.1	PR Dumb-waiters	N/A	N/A	8.11.5.4	1-1 to 12-31	N/A	N/A	8.11.5.4	60	No	No	No	No
ASME A18.1	PR Platform Lifts	N/A	N/A	10.3.1	1-1 to 12-31	10.3.2	10.3.2	10.3.3	60	No	No	No	No
ASME A18.1	PR Stairway Chair Lifts	N/A	N/A	10.3.1	1-1 to 12-31	N/A	N/A	N/A	NA	No	No	No	No

Notes:

- (1) Where filing with the Department is not required, Owner shall perform inspection and maintain log of each inspection/test performed as required by the *New York City Building Code* and available to the Department upon request.
- (2) For Category 1 Inspection/Test, a minimum six (6) month time interval from the date of previous calendar year Category 1 Inspection/Test.
- (3) See Article 304
- (4) Dismantled devices do not require Category 1, 3 or 5 Tests.
- (5) Category 5 Tests are due by the last day of the month on the 5th anniversary. For example, if the Category 5 Test was last performed on 7/1/09, then the Category 5 Test must be performed by 7/31/14.